

SIMATIC DP, IM151-7 CPU FOR ET200S, 128 KB WORKING MEMORY INTEGR. PROFIBUS DP INTERFACE (9 PIN SUB-D, FEMALE) AS DP SLAVE, W/O BATTERY SIMATIC MMC REQUIRED



General information	
Hardware product version	01
Firmware version	V3.3
Engineering with	
• Programming package	V5.5 + SP1 or higher or V5.2 + SP1 or higher + HSP 219
Supply voltage	
Rated value (DC)	24 V
permissible range, lower limit (DC)	19.2 V
permissible range, upper limit (DC)	28.8 V
Reverse polarity protection	Yes; against destruction
external protection for power supply lines (recommendation)	2 A min.
Mains buffering	
• Mains/voltage failure stored energy time	5 ms
Input current	
Inrush current, max.	1.8 A; Typical
I^2t	0.09 A ² ·s
from supply voltage 1L+, max.	320 mA; 410 mA with DP master module

Output current	
for backplane bus (5 V DC), max.	700 mA
Power loss	
Power loss, typ.	4.2 W
Memory	
Work memory	
• integrated	128 kbyte
• expandable	No
• Size of retentive memory for retentive data blocks	64 kbyte
Load memory	
• Plug-in (MMC)	Yes
• Plug-in (MMC), max.	8 Mbyte
• Data management on MMC (after last programming), min.	10 y
Backup	
• present	Yes; Ensured by SIMATIC Micro Memory Card (maintenance-free)
CPU processing times	
for bit operations, typ.	0.06 µs
for word operations, typ.	0.12 µs
for fixed point arithmetic, typ.	0.16 µs
for floating point arithmetic, typ.	0.59 µs
CPU-blocks	
Number of blocks (total)	1 024; (DBs, FCs, FBs); the maximum number of loadable blocks can be reduced by the MMC used.
DB	
• Number, max.	1 024; Number range: 1 to 16000
• Size, max.	64 kbyte
FB	
• Number, max.	1 024; Number range: 0 to 7999
• Size, max.	64 kbyte
FC	
• Number, max.	1 024; Number range: 0 to 7999
• Size, max.	64 kbyte
OB	
• Description	See S7-300 operation list
• Size, max.	64 kbyte
• Number of free cycle OBs	1; OB 1
• Number of time alarm OBs	1; OB 10
• Number of delay alarm OBs	2; OB 20, 21

• Number of cyclic interrupt OBs	4; OB 32, 33, 34, 35
• Number of process alarm OBs	1; OB 40
• Number of DPV1 alarm OBs	3; OB 55, 56, 57
• Number of startup OBs	1; OB 100
• Number of asynchronous error OBs	6; OB 80, 82, 83 (for centralized I/O only, not for distributed I/O), 85, 86, 87
• Number of synchronous error OBs	2; OB 121, 122
Nesting depth	
• per priority class	16
• additional within an error OB	4
Counters, timers and their retentivity	
S7 counter	
• Number	256
Retentivity	
— adjustable	Yes
— lower limit	0
— upper limit	255
— preset	Z 0 to Z 7
Counting range	
— lower limit	0
— upper limit	999
IEC counter	
• Number	Unlimited (limited only by RAM capacity)
S7 times	
• Number	256
Retentivity	
— adjustable	Yes
— lower limit	0
— upper limit	255
— preset	No retentivity
Time range	
— lower limit	10 ms
— upper limit	9 990 s
IEC timer	
• present	Yes
• Type	SFB
• Number	Unlimited (limited only by RAM capacity)
Data areas and their retentivity	
Flag	
• Number, max.	256 byte
• Retentivity available	Yes; MB 0 to MB 255

• Retentivity preset	MB 0 to MB 15
• Number of clock memories	8; 1 memory byte
Data blocks	
• Number, max.	1 024; Number range: 1 to 16000
• Size, max.	64 kbyte
• Retentivity adjustable	Yes; via non-retain property on DB
• Retentivity preset	Yes
Local data	
• per priority class, max.	32 kbyte; Max. 2048 bytes per block
Address area	
I/O address area	
• Inputs	2 048 byte
• Outputs	2 048 byte
of which distributed	
— Inputs	2 048 byte
— Outputs	2 048 byte
Process image	
• Inputs	2 048 byte
• Outputs	2 048 byte
• Inputs, adjustable	2 048 byte
• Outputs, adjustable	2 048 byte
• Inputs, default	128 byte
• Outputs, default	128 byte
Digital channels	
• Inputs	16 336
— of which central	496
• Outputs	16 336
— of which central	496
Analog channels	
• Inputs	1 021
— of which central	124
• Outputs	1 021
— of which central	124
Hardware configuration	
Number of modules per system, max.	63; Centralized
Mounting rail	
• Number of mounting rails that can be used	1
• Length of mounting rail, max.	Station width: ≤ 1 m or < 2 m
Time of day	
Clock	

<ul style="list-style-type: none"> • Hardware clock (real-time) • retentive and synchronizable • Backup time • Deviation per day, max. • Behavior of the clock following POWER-ON • Behavior of the clock following expiry of backup period 	<p>Yes</p> <p>Yes</p> <p>6 wk; At 40 °C ambient temperature, typically</p> <p>10 s; Typ.: 2 s</p> <p>Clock continues running after POWER OFF</p> <p>Clock continues to run with the time at which the power failure occurred</p>
Operating hours counter	
<ul style="list-style-type: none"> • Number • Number/Number range • Range of values • Granularity • retentive 	<p>1</p> <p>0</p> <p>0 to 2³¹ hours (when using SFC 101)</p> <p>1 hour</p> <p>Yes; Must be restarted at each restart</p>
Clock synchronization	
<ul style="list-style-type: none"> • supported • to MPI, master • to MPI, slave • to DP, master • to DP, slave • in AS, master • in AS, slave 	<p>Yes</p> <p>Yes</p> <p>Yes</p> <p>Yes; With DP slave only slave clock</p> <p>Yes</p> <p>No</p> <p>No</p>
Interfaces	
Interfaces/bus type	1 x MPI/PROFIBUS DP
Number of PROFINET interfaces	0
Number of wireless interfaces	0
1. Interface	
Interface type	Integrated RS 485 interface
Physics	RS 485
Isolated	Yes
Power supply to interface (15 to 30 V DC), max.	80 mA
Functionality	
<ul style="list-style-type: none"> • MPI • PROFIBUS DP master • PROFIBUS DP slave • Point-to-point connection 	<p>Yes</p> <p>No</p> <p>Yes; active / passive</p> <p>No</p>
MPI	
<ul style="list-style-type: none"> • Transmission rate, max. 	12 Mbit/s
Services	
— PG/OP communication	Yes
— Routing	Yes; With master module
— Global data communication	Yes

— S7 basic communication	Yes
— S7 communication	Yes; Only server, configured on one side
— S7 communication, as client	No
— S7 communication, as server	Yes
DP slave	
• GSD file	The latest GSD file is available on the Internet (http://www.siemens.com/profibus-gsd)
• Transmission rate, max.	12 Mbit/s
• automatic baud rate search	Yes; only with passive interface
• Address area, max.	32
• User data per address area, max.	32 byte; Up to max. size of the transfer memory
Services	
— PG/OP communication	Yes
— Routing	Yes; Only with active, integrated DP slave interface and inserted DP master module in DP master mode
— Global data communication	No
— S7 basic communication	No
— S7 communication	Yes; Only server, configured on one side
— S7 communication, as client	No
— S7 communication, as server	Yes
— Direct data exchange (slave-to-slave communication)	Yes
— DPV1	No
Transfer memory	
— Inputs	244 byte
— Outputs	244 byte

2. Interface

Interface type	External interface via master module 6ES7138-4HA00-0AB0
Physics	RS 485
Isolated	Yes
Power supply to interface (15 to 30 V DC), max.	No
Functionality	
• MPI	No
• PROFIBUS DP master	Yes
• PROFIBUS DP slave	No
DP master	
• Transmission rate, max.	12 Mbit/s
• Number of DP slaves, max.	32; Per station
Services	
— PG/OP communication	Yes
— Routing	Yes
— Global data communication	No

— S7 basic communication	Yes; I blocks only
— S7 communication	Yes; Only server, configured on one side
— S7 communication, as client	No
— S7 communication, as server	Yes
— Equidistance	Yes
— Isochronous mode	No
— SYNC/FREEZE	Yes
— Activation/deactivation of DP slaves	Yes
— Number of DP slaves that can be simultaneously activated/deactivated, max.	8
— Direct data exchange (slave-to-slave communication)	Yes
— DPV1	Yes
Address area	
— Inputs, max.	2 kbyte
— Outputs, max.	2 kbyte
User data per DP slave	
— Inputs, max.	244 byte
— Outputs, max.	244 byte
Isochronous mode	
Isochronous operation (application synchronized up to terminal)	No
Communication functions	
PG/OP communication	Yes
Data record routing	Yes; With DP master module
Global data communication	
• supported	Yes
• Number of GD loops, max.	8
• Number of GD packets, max.	8
• Number of GD packets, transmitter, max.	8
• Number of GD packets, receiver, max.	8
• Size of GD packets, max.	22 byte
• Size of GD packet (of which consistent), max.	22 byte
S7 basic communication	
• supported	Yes
• User data per job, max.	76 byte
• User data per job (of which consistent), max.	76 byte; 76 bytes (with X_SEND or X_RCV); 64 bytes (with X_PUT or X_GET as server)
S7 communication	
• supported	Yes
• as server	Yes

<ul style="list-style-type: none"> • as client • User data per job, max. • User data per job (of which consistent), max. 	<p>No</p> <p>See online help of STEP 7 (shared parameters of the SFBs/FBs and of the SFCs/FCs of S7 Communication)</p> <p>See online help of STEP 7 (shared parameters of the SFBs/FBs and of the SFCs/FCs of S7 Communication)</p>
Number of connections	
<ul style="list-style-type: none"> • overall 	12
<ul style="list-style-type: none"> • usable for PG communication <ul style="list-style-type: none"> — reserved for PG communication — adjustable for PG communication, min. — adjustable for PG communication, max. 	11 1 1 11
<ul style="list-style-type: none"> • usable for OP communication <ul style="list-style-type: none"> — reserved for OP communication — adjustable for OP communication, min. — adjustable for OP communication, max. 	11 1 1 11
<ul style="list-style-type: none"> • usable for S7 basic communication <ul style="list-style-type: none"> — reserved for S7 basic communication — adjustable for S7 basic communication, min. — adjustable for S7 basic communication, max. 	10 0 0 10
<ul style="list-style-type: none"> • usable for routing 	4; As slave only with active interface, with IM 151-7 CPU as DP master
S7 message functions	
Number of login stations for message functions, max.	12; Depending on the configured connections for PG/OP and S7 basic communication
Process diagnostic messages	Yes; ALARM_S, ALARM_SC, ALARM_SQ, ALARM_D, ALARM_DQ
simultaneously active Alarm-S blocks, max.	300
Test commissioning functions	
Status block	Yes; Up to 2 simultaneously
Single step	Yes
Number of breakpoints	4
Status/control	
<ul style="list-style-type: none"> • Status/control variable 	Yes
<ul style="list-style-type: none"> • Variables 	Inputs, outputs, memory bits, DB, times, counters
<ul style="list-style-type: none"> • Number of variables, max. <ul style="list-style-type: none"> — of which status variables, max. — of which control variables, max. 	30 30 14
Forcing	
<ul style="list-style-type: none"> • Forcing 	Yes
<ul style="list-style-type: none"> • Forcing, variables 	Inputs, outputs

• Number of variables, max.	10
Diagnostic buffer	
• present	Yes
• Number of entries, max.	500
— adjustable	No
— of which powerfail-proof	100; Only the last 100 entries are retained
• Number of entries readable in RUN, max.	499
— can be set	Yes; From 10 to 499
— preset	10
Service data	
• can be read out	Yes
Interrupts/diagnostics/status information	
Alarms	Yes
Diagnostic functions	Yes
Diagnostics indication LED	
• Group error SF (red)	Yes
• Monitoring 24 V voltage supply ON (green)	Yes
Potential separation	
between PROFIBUS DP and all other circuit components	Yes
Permissible potential difference	
between different circuits	75 V DC/60 V AC
Isolation	
Isolation tested with	500 V DC
Degree and class of protection	
IP degree of protection	IP20
Configuration	
Configuration rules	max. 63 peripheral modules per station; station width < 1 m or < 2 m; max. 10 A per load group (power module); master interface module on right next to IM 151-7 CPU (X2 interface)
Configuration software	
• STEP 7 Lite	No
Programming	
• Command set	see instruction list
• Nesting levels	8
• System functions (SFC)	see instruction list
• System function blocks (SFB)	see instruction list
Programming language	
— LAD	Yes
— FBD	Yes

— STL	Yes
— SCL	Yes; Optional
— CFC	Yes; Optional
— GRAPH	Yes; Optional
— HiGraph®	Yes; Optional
Know-how protection	
• User program protection/password protection	Yes
• Block encryption	Yes; With S7 block Privacy
Cycle time monitoring	
• lower limit	1 ms
• upper limit	6 000 ms
• adjustable	Yes
• preset	150 ms
Dimensions	
Width	60 mm; DP master module: 35 mm
Height	119.5 mm
Depth	75 mm
Weights	
Weight, approx.	200 g; DP master module: Approx. 100 g
last modified:	08/12/2017